

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50362278

Blatt *Page*
0001

Ihr Zeichen *Client Reference*
L.Q.J

Unser Zeichen *Our Reference*
02-liangi-50059795 001

Ausstellungsdatum *Date of Issue*
23.11.2016 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Jiangsu Tonglin Electric
Co., Ltd.
666# Gangmao RD,
Economic Development Zone
Yangzhong City, Jiangsu 212200
P.R. China

Fertigungsstätte *Manufacturing Plant*
Jiangsu Tonglin Electric
Co., Ltd.
666# Gangmao RD,
Economic Development Zone
Yangzhong City, Jiangsu 212200
P.R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1419041264

Geprüft nach *Tested acc. to*
EN 50618:2014

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

PV-Cables (Electric Cables for Photovoltaic Systems)

Type Designation : H1Z2Z2-K 1x 1,5...35mm² (Tonglin) 12
Rated Voltage : DC 1.5kV
AC U₀/U 1/1kV
Ambient Temperature : -40°C to +90°C
Max. Temperature : 120°C
at Conductor

12

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

